



Certificate of Compliance

This certificate is issued for the following:

Indicating Butterfly Valves

**Models 25G-300, Model 25W-300, and Model 25L-300
Sizes 50, 65, 80 and 100 mm DN**

Maximum Working Pressure: 300 psi (2070 kPa)

Prepared For:

Tianjin Galaxy Valve Co., Ltd.
No. 15 Tianhua Road
Balitai Industrial Area
Jinnan District, Tianjin
Peoples Republic of China, 300350

Manufactured at:

Tianjin Galaxy Valve Co., Ltd.
No. 15 Tianhua Road
Balitai Industrial Area
Jinnan District, Tianjin
Peoples Republic of China, 300350

FM Approvals Class: 1112, dated August 2006

Approval Identification: 0003058730

Approval Granted: May 2, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D.B. Fuller'.

David B. Fuller
AVP – Manager, Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group